

4240 Passmore Upper Road, Winlaw BC, V0G 2J0
 250-226-7339
 test@passmorelaboratory.ca
 passmorelaboratory.ca

Attention	Project
Client Slocan River Streamkeepers for SIFCO Water M	Project Info

CERTIFICATE OF ANALYSIS

<u>Analyses</u>	<u>Method Description</u>	<u>Reference</u>
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B
E. coli	MF Partition on NA-MUG medium	APHA 9222I
Fecal Coliforms	Membrane Filtration on mFC medium	APHA 9222D

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA.

Processed by: Mechelle Babic

Jennifer Yeow,
 Lab Manager



Please call or Email for with any questions, feedback, or more information

ANALYTICAL RESULTS

Sample ID Winlaw WQ01 Sample # 1
Sample Date/Time 2023-03-29 10:22 AM Source: Winlaw creek

Date/Time on test 2023-03-30 3:00 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
Coliforms, Total	24	CFU/100mL	1
Verified E.coli	less than 1	CFU/100mL	1
Fecal (Thermotolerant) Coliforms	less than 1	CFU/100mL	1
Turbidity	0.312	NTU	0.1
Conductivity	124.2	µS/cm @25°C	0.1

Comments This sample does not meet Canadian drinking water guidelines for the Total Coliform test. Total Coliforms are not associated with human infection but may indicate the presence of other harmful organisms.

Sample ID Trozzo WQ01 Sample # 2
Sample Date/Time 2023-04-06 Source: Trozzo creek

Date/Time on test 2023-04-06 6:00 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
Coliforms, Total	3	CFU/100mL	1
Verified E.coli	less than 1	CFU/100mL	1
Fecal (Thermotolerant) Coliforms	1	CFU/100mL	1
Turbidity	0.207	NTU	0.1
Conductivity	99.44	µS/cm @25°C	0.1

Comments This sample does not meet Canadian drinking water guidelines for tests performed.

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/100mL	Colony Forming Units per 100 milliliters
MAC	Maximum Acceptable Concentration
Matrix	SW = Surface water, TW =Treated water, DW= Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References